


LEGEND

- REFER TO GENERAL INFORMATION SHEET A0.0 FOR OCCUPANT LOAD AND EGRESS CALCULATIONS.
- FIRE EXTINGUISHERS: COMPLY WITH PRODUCT REQUIREMENTS OF NFPA 10 AND APPLICABLE CODES, WHICHEVER IS MORE STRINGENT.
 - TYPE FE: DRY CHEMICAL TYPE FIRE EXTINGUISHERS: CAST STEEL TANK, WITH PRESSURE GAGE, CLASS A,B,C, SIZE 10.
- FIRE EXTINGUISHER CABINETS (FEC).
 - BOX: SEMI- RECESSED 20 GAGE COLD ROLLED STEEL WITH WHITE BAKED ENAMEL FINISH.
 - TRIM: FLAT TRIM 1, 3/4 INCHES WIDE BY 5/16 INCH (AT GYPSUM BOARD, MASONRY AND TILE SURFACES).
 - DOOR: SOLID PANEL, 20 GAGE COLD ROLLED STEEL WITH WHITE BAKED ENAMEL FINISH, MANUFACTURER'S STANDARD LATCH, CONTINUOUS (PIANO TYPE) HINGE, VERTICAL LETTERING READING "FIRE EXTINGUISHER".

GENERAL LIFE SAFETY NOTES



ISSUE
11-03-11 ISSUED FOR PERMIT/PRICING

HARRELL
ARCHITECTS, LP

9575 Katy Frwy., #200
Houston, Texas 77024
tel: 713.722.7071
fax: 713.722.7072

CONSULTANTS
Holste & Associates, Inc.
MEP Engineers

PROJECT NAME



Cafe Express Restaurant

PROJECT ADDRESS
3800 SW. Freeway, Suite 124
Houston, Texas 77027

PROJECT NUMBER
11039

SHEET NAME

FLOOR LIFE SAFETY PLAN

SHEET NUMBER

A2.4