



**ELECTRICAL NOTES:**

1. POWER SUPPLY FOR EXIT SIGNS AND EMERGENCY LIGHTS SHALL BE PROVIDED BY THE PREMISES WIRING SYSTEM. IN THE EVENT OF NORMAL POWER FAILURE ILLUMINATION SHALL BE AUTOMATICALLY PROVIDED FROM AN EMERGENCY POWER-BATTERY BACK UP OR FROM AN ON SITE EMERGENCY GENERATION SET. TO ENSURE CONTINUED ILLUMINATION FOR A DURATION OF NOT LESS THAN 90 MINUTES.
2. BE-LEVEL SWITCHING: (SECTION 805.2.1)  
BI-LEVELS SWITCHING USED FOR EACH AREA LESS THAN 250 SF. THAT IS REQUIRED TO HAVE A MANUAL CONTROL SHALL BE SHALL ALSO ALLOW THE OCCUPANT TO REDUCE THE CONNECTED LIGHTING LOAD IN A REASONABLE UNIFORM ILLUMINATION PATTERN AT LEAST 50 PERCENT.  
EXCEPTIONS:  
1. AREAS THAT HAVE ONLY 1 LUMINAIRE.  
2. AREAS THAT ARE CONTROLLED BY AN OCCUPANT-SENSING DEVIDE.  
3. CORRIDORS, STOREROOMS, RESTROOM, OR PUBLIC LOBBIES.  
4. GUEST ROOMS.

**ELECTRICAL FIXTURES SCHEDULE & LEGEND**

	2x4' RECESSED FLUORESCENT LIGHT FIXTURES WHITEWAY MODEL 3RF-48P (3 LAMPS), 120V, 96W (32W EA.) OR EQUAL. PROVIDE PLASTIC SHIELD IN KITCHEN AND FOOD PREPERATION AREAS
	2x2' RECESSED FLUORESCENT LIGHT FIXTURES WHITEWAY MODEL 3RF-48P (2 LAMPS), 120V, 50W (24W EA.) OR EQUAL. PROVIDE PLASTIC SHIELD IN KITCHEN AND FOOD PREPERATION AREAS
	TRACK LIGHT
	CEILING FLUSH 60W, 120V
	'SURE-LITES' EXIT LIGHT, UN SERIES W/ POWER PACK 90 MIN.
	'SURE-LITES' EMERGENCY LIGHT PLB SERIES W/ POWER PACK 90 MIN.
	JUNCTION BOX
	RECEPTACLE OUTLETS, 120V.
	CEILING ELEC. OUTLET
	120 VOLT GROUND FAULT INTERRUPTER
	FLOOR ELEC. OUTLET
	EXHAUST FANS, DUCTED THRU ROOF.
	SWITCHES- 'BRYANT' CS 20-W
	3-WAY SWITCH, S4 4-WAY, S2 - 2 POLE SL- SWITCH W/ LIGHTED TOGGLE
	SWITCHES- WITH REMOTE CONTROL DEVICE CS 20-W AND INDICATOR PILOT LIGHT, WITH 30 MIN AUTO OFF & INTEGRATED MOVEMENT SENSOR
	T.C. TIMER CONTROL 24 HRS, 7 DAYS WITH E. BATTERY BACKUP POWER FOR 90 MIN.
	P.C. PHOTOCELL CONTROLLED WITH E. BATTERY BACKUP POWER FOR 90 MIN.
	SHUNT TRIP

<p>SCHLOTZSKY'S VICTORY LAKES TOWN CENTER TRACK 7A, NEC INTERSTATE HWY 45 &amp; F.M.646 LEAGUE CITY TEXAS 77000</p>	<p><b>TRIMCOS DESIGN &amp; ENG.</b></p> <p>11222 RICHMOND AVE. SUITE# 225 HOUSTON TX, 77082 (281) 558-0696 F-3926</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>Rev.</th> <th>By</th> <th>Date</th> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </table>	Rev.	By	Date						
Rev.	By	Date									

**ARCH**  
Woo Associates, L.L.C.

ARCHITECTS - PLANNERS  
13734 Bromford Green Dr.  
Houston, TX. 77083  
(832) 228-8128

Date	07-14-2010
Scale	AS SHOWN
Drawn by	
Job#:	
SHEET NO:	E-01